



Global Certification Bureau

Corrective Action Form QMS-P08-F01

Department/process: HSE	
Audit Date: 2025-12-17	NCR No.: 4
Auditor Name: Eng. Islam Hissen	
Clause No.: Clause 8.1	Audit Criteria: ISO 45001:2018
Finding Description: NC-04: Expired Fire Extinguishers Inspection of the administrative building revealed fire extinguishers bearing inspection labels with expired dates at the time of the audit. while ISO 45001:2018 - Clause 8.1 REQUIRE THAT The organization shall implement operational controls to eliminate hazards and reduce OH&S risks.	
Evidence: administrative building revealed fire extinguishers labels .	
Criteria from ISO Standard: REQUIRE THAT The organization shall implement operational controls to eliminate hazards and reduce OH&S risks.	
Auditor Name: Eng. Islam Hissen	Signature
Proposed Action date: 2026-02-18	Due Date: 2026-02-18
Correction: Send letter for Supplier updating inspection	
Root Cause Analysis: No follow up plan for extinguishers due to contract with supplier for monthly check	
Corrective Action: Add all fire equipment to maintenace plan for regular check	
<input checked="" type="checkbox"/> Action Accepted	<input type="checkbox"/> Action Not Accepted
Comments: follow up required in next audit	
Closed <input checked="" type="checkbox"/>	Close Date: 2025-12-18